

Annexure C



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 38/2025

Dated: 22/01/2025

It is certified that an inspection team headed by Bigukumar T.S. Junior Health Inspector
(Name of Officers with designation) from FHC Eloor PHED

inspected the St. Ann's Public School Eloor

(Name & Address of the school) on 21/01/25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. KWA/CDL-ALS/16915/23-24 dated 27.05.24

of Kerala Water Authority Lab Aluva 683101 (PHED Lab) certified that the
St. Ann's Public School Eloor (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1yr

Signature with Seal: [Signature]
Name: Dr. Samitha Padikkal
Designation: Medical officer in charge
Name & Address of the Office / Department :

To
.....
(Name & Address of the Institution)



FHC Eloor
മെഡിക്കൽ ഓഫീസർ ഇൻ ചാർജ്ജ്
കുടുംബാരോഗ്യ കേന്ദ്രം എലൂർ
എറണാകുളം ജില്ല. പിൻ: 683 501

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Telephone: 0484-2623576
web@kwa.aluva@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, ALUVA -683101
WATER TEST REPORT

Report No: KWA/QCDL-A/S/16915/23-24

Report Issue Date: 27.05.2024

Customer Name & Address St:Ann's Public School Eloor C/O Principal Udyogamandal P O	Date of Receipt of Payment	15.05.2024
	Date of Sample received	16.05.2024
	Sample given by	MO LC, FHC Eloor
	Sample Code	ALY/S/16915/5/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Well
	Sample Quantity	2 Litre
	Test performing dates :	From : 22.05.24 to 24.05.24

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Residual Chlorine	mg/L	IS 3025 (Part 26)-1986(Reaffirmed 2019)	0.2	BDL(DL=0.2)

Remarks- **DL** : Detectable Limit
BDL Below Detectable Limit

- NB-1) The result stated above related only to the sample(s) submitted for testing by the customer
 2) The samples retain for 15 days from the end date of analysis
 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Authorized By

End of Report

CHEMIST
Quality Control District
Kerala Water Authority
Aluva

KWA/QCDL/ALY/01-2020	Issue Date : 04.10.2020
Rev.No: 02	Rev.Date : 30/07/2023
Page 1 of 1	





Telephone: 0484-2612526
email: qcddlaluva@gmail.com

KERALA WATER AUTHORITY



QUALITY CONTROL DISTRICT LAB, ALUVA -683101

WATER TEST REPORT

ULR NO: TC9552240000022295F

Report Issue Date: 27.05.2024

Customer Name & Address St:Ann's Public School Eloor C/O Principal Udyogamandal P O	Date of Receipt of Payment	15.05.2024
	Date of Sample received	16.05.2024
	Sample given by	MO I/C, FHC Eloor
	Sample Code	ALY/S/16915/5/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Well
	Sample Quantity	2 Litre
	Test performing dates :	From : 22.05.24 to 24.05.24

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS 10500-2012	Result
1	Fluoride (as F ⁻)	mg/L	IS 3025 (Part 60)-2008(Reaffirmed 2013)	2	BDL(DL-0.2)
2	Acidity	mg/L	IS 3025 (Part 22)-1986(Reaffirmed 2019)		28
3	Electrical conductivity at 25 ^o - C	micromhos/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)		120
4	Colour	HU	IS 3025 (Part 4)-1983(Reaffirmed 2021)	5	1
5	Odour	-	IS 3025 (Part 5)-2018	Agreeable	Agreeable
6	Turbidity	NTU	IS 3025 (Part10)-2023	1.0	0.83
7	pH at 25 ^o C	-	IS 3025 (Part 11)-2022)	6.5 to 8.5	5.99
8	Total Alkalinity	mg/L	IS 3025 (Part 23)-2023	200	16
9	Sulphate (as SO4)	mg/L	IS 3025 (Part 24)-2022	200	12.71
10	Total Dissolved Solids (TDS) @180 ^o c	mg/L	IS 3025 (Part 16)-2023	500	60
11	Total Hardness (as CaCO3)	mg/L	IS 3025 (Part21)-2009(Reaffirmed 2019)	200	42
12	Calcium (as Ca)	mg/L	IS 3025 (Part 40)-1991(Reaffirmed 2019)	75	12.8
13	Magnesium (as Mg)	mg/L	IS 3025 (Part 46)-1994(Reaffirmed 2019)	30	2.43
14	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	12.2
15	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2003 (Reaffirmed 2019)	1	0.1
16	Nitrate (as NO3)	mg/L	APHA 23rd Edition(UV Screening Method) 2017	45	24

Remarks - DL : Detectable Limit
BDL - Below Detectable Limit

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Signature
Authorized By

End of Report

 KWA/QC/DL/ALY/01-2020 Rev No: 02	Issue Date : 04.10.2020 Page 1 of 1	CHEMIST Quality Control District Lab Kerala Water Authority Aluva
---	--	--